



2009 WATER QUALITY REPORT

DEAR CITY OF OPA-LOCKA WATER CONSUMER:

The City of Opa-locka is committed to provide its customers with high quality drinking water. The drinking water in the City of Opa-locka is purchased directly from Miami-Dade County Water and Sewer Department (WASD).

We are pleased to inform you that our drinking water, supplied by WASD, is safe and has met all federal, state and local standards for drinking water during 2009. The attached brochure illustrates our 2009 water quality and what it means to you.

The City of Opa-locka routinely monitors for lead, copper and coliform bacteria in your drinking water, in accordance with the Federal Regulations. The data presented in the following table shows the results for the most recent monitored period.

Contaminant and Unit of Measurement	Federal MCL	MCLG Federal Level Goal	State MCL	Violation	Year Tested	Level	Likely Source of Contamination
Total Coliform Bacteria	5%	0	5%	NO	2009	None	Naturally present in the environment
Lead (ppb)**	AL=15	0	AL=15	NO	2008/9	2 homes out of 31 (0%) exceeded AL	Corrosion of household plumbing systems
Copper (ppm)**	AL=1.3	1.3	AL=1.3	NO	2008/9	0.96 homes out of 31 (0%) exceeded AL	Corrosion of household plumbing systems

** percentile value reported. If the 90th percentile value does not exceed the AL (less than 10%) of the homes have levels above the AL), the system is in compliance and is utilizing the prescribed corrosion control measures.

This report will not be mailed to individual residents/citizens of Opa-locka

Should you have any questions, please feel free to contact the City of Opa-locka Public Utilities Department Customer Service Office at 305-953-2828